

Asian Institute of Technology

(For local calls, dial 02 before the

tel/fax nos.)

(66-2)524-5505 Tel: Tel:

http://www.ait.ac.th

(66-2)524-5501 Tel: (66-2)524-5523

(66-2)524-6059 Fax: gtelab.ait.mail@gmail.com

Km. 42 Phaholyothin Highway Klong Luang

Pathumthani 12120 Pathum Thani 12120 Thailand

Street Address:

Klong Luang, Thailand

Postal Address:

P.O. Box 4

LABORATORY TESTS ON CONSTRUCTION SAFETY-NET

Issued to:

School of Engineering and Technology (SET)

TEMCO., LTD.

Address:

8th Floor, Thaniya Bldg.,

62 Silom Road, Suriyawong, Bangrak,

Bangkok, 10500 Thailand

Sample description:

Polyester Safety Net 15x15 mm. (T-2018)

Date Tested:

6 August 2018

Date Submitted:

8 August 2018

Testing Atmosphere:

 $23 \pm 2^{\circ}$ C temperature and $65 \pm 5\%$ humidity

Test Method: ASTM D638

Test Results:

Asian Center for Soil Improvement and Geosynthetics (ACSIG)

Properties	Unit	Measure Tensile Strength				
Tensile Strength	kgf per strand	Trial 1	Trial 2	Trial 3	Mean	
		36.6	32.6	34.5	34.6	

DISCLAIMER:

TEMCO., LTD. is hereby forewarned that this report covers only the results of the Construction Safety Net sample that was received and tested according to the specified ASTM test standards and testing atmosphere of 23 \pm 2°C temperature and 65 \pm 5% humidity. This certificate, however, may not represent the condition of other products with the same nomenclature. This certificate will be kept in the active file for six months after which it will be disposed.

Submitted by:

Ms.Terdkiad Nontapot

Manager, ACSIG

Asian Institute of Technology

Dr. Kuo-Chieh Chao

Director, ACSIG

Asian Institute of Technology





Asian Institute of Technology

Asian Center for Soil Improvement and Geosynthetics (ACSIG)

P.O. Box 4 Klong Luang, Pathumthani 12120

Postal Address:

Thailana Th

Street Address:

Km. 42 Phaholyothin Highway

Klong Luang

Pathum Thani 12120

Tel: (66-2)524-5505 Y Tel: (66-2)524-5501 Tel: (66-2)524-5523

tel/fax nos.)

Fax: (66-2)524-6059 e-mail gtelab.ait.mail@gmail.com

(For local calls, dial 02 before the

http://www.ait.ac.th

LABORATORY TESTS ON CONSTRUCTION SAFETY-NET

Issued to:

School of Engineering and Technology (SET)

TEMCO., LTD.

Address:

8th Floor, Thaniya Bldg.,

62 Silom Road, Suriyawong, Bangrak,

Bangkok, 10500 Thailand

Sample description:

Polyester Safety Net 15x15 mm. (T-2018)

Date Tested:

6 August 2018

Date Submitted:

8 August 2018

Testing Atmosphere:

 23 ± 2 °C temperature and 65 ± 5 % humidity

Test Method: ASTM D638

Test Results:

Properties	Unit	Measure Tensile Strength				
Tensile Strength	kgf per strand	Trial 1	Trial 2	Trial 3	Mean	
		36.6	32.6	34.5	34.6	

DISCLAIMER:

TEMCO., LTD. is hereby forewarned that this report covers only the results of the Construction Safety Net sample that was received and tested according to the specified ASTM test standards and testing atmosphere of $23 \pm 2^{\circ}$ C temperature and $65 \pm 5\%$ humidity. This certificate, however, may not represent the condition of other products with the same nomenclature. This certificate will be kept in the active file for six months after which it will be disposed.

Submitted by:

Ms.Terdkiad Nontapot

Manager, ACSIG

Asian Institute of Technology

Dr. Kuo-Chieh Chao

Director, ACSIG

Asian Institute of Technology